

Models for Trade Waste Applications

TDM10000

TDP10000

Trade Waste Controllers

USER MANUAL

Dec 2008 Version 5.0



Congratulations	3
Where to find the serial number	4
Section contents	5
Installation guidelines - Section 1	6
System configuration - Section 2	10
Manufacturer's Warranty - Section 3	30

Unit 1, 23
Richland Avenue
Coopers Plains QLD 4108
PO Box 71
Coopers Plains QLD 4108
AUSTRALIA

t: + 61 7 3274 4750
f: + 61 7 3274 4736
w: www.aquariustech.com.au
e: info@aquariustech.com.au

Aquarius Water Treatment Controllers

Congratulations

We know you will be happy with your decision to purchase a new Aquarius Technologies Controller. These units are now supplied with standard features that are considered optional extras in most other systems, if available at all.

The updated software now incorporates our newly released Aquarius Proprietary Logic (APL), which has capabilities to control monitoring and responses to much tighter tolerances that were ever possible in earlier models.

You also have the comfort of knowing that these models are capable of being upgraded by connecting to a notebook computer, locally or via the optional cellular communications package. They are also scalable in terms of adding modules to expand capacity over time.

Let us help you to learn about your new Controller. This manual will take you through all of the functions available from the keyboard and display, and provide a clear and logical sequence for processing the configuration settings.

Please also take the time to send us details of the Installation on the Registration Form provided. This will enable us to provide the very best level of technical support should you need to contact us for any reason.


Models covered by this Manual

- Models for Trade Waste Control - 'TD' Series

Where to find the serial number



Model TD10000



Serial Identification Label

All Aquarius Technologies Controllers are manufactured with a Serial Identification Label (SIL).

This will be affixed to the wall of the controller, on the outside face on the right side.

The label is the best reference for making inquiries for service or Technical Assistance.

Any controller that does not show evidence of the SIL may have the warranty voided.

Key data being:

Model: e.g. TD10000

This is actual Controller model and indicates the configuration.

Build: e.g. OCT-05

Would indicate this controller was manufactured in October 2005

Serial No: e.g. 0510PH11011

Is the specific serial number for this Controller

Section Contents

1

Installation Guidelines

Minimum System Requirements	6
-----------------------------	---

Maintenance & Care of Sensors

• Cleaning Flow/Conductivity/Temp sensor	7
• Cleaning pH/ORP sensor	7

Accessories & Spare Parts

• Reagents	7
• Sensors	7
• Peristaltic Pumps	7
• Test Meters	7

Routine Testing	7
-----------------	---

Warnings	8
----------	---

Regular Inspections & Maintenance	8
-----------------------------------	---

2

System Configuration

Aquarius Control Systems	10
--------------------------	----

Screen	10
--------	----

Buttons	10
---------	----

• Default Screen	11
• Calibration – Access from the CAL button	11
• Combination Calibration Mode	11
• Erase WUM Totals Mode	11
• pH Calibration Mode	11
• ORP Verification Mode	12
• Cond/Temp Mode (if used)	12
• Steps in Temperature Calibration	12
• Steps in Conductivity Calibration	12
• Erase Calibration Mode	13
• Panel Selection Mode	13
• Factory Alert Screen	13
• Source Data Screen	13

2

System Configuration

Set Screens Menu	14
------------------	----

• Key Pad Function	14
• Set Time & Date Screen	15
• Set Data Logger Screen	15
• Set Alarms Screen	15
• Set Alarms Screen - Name & Phone	16
• Set Conductivity Screen (if used)	16
• Set ORP Screen (if used)	17
• Set pH Screen	18
• Set Water Usage Meter Screen	19
• Set Protocol Screen	19

Read Mode	19
-----------	----

• Alarm Read Screen	20
• Sensors Status Screen	20
• Conductivity Read Screen	20
• ORP Read Screen	21
• pH Read Screen	21
• Water Usage Meter Read Screen	21
• Protocol Read Screen	22

Tank Alarm (with wiring instructions)	22
---------------------------------------	----

Data Logging & Communications Setup	23
-------------------------------------	----

• Hyper Terminal Set Up	23
• GSM modem set up	24
• Adding a SIM card to GSM modem	24
• Adding phones nos for Alarms	24
• Using AquaGuard 2 software	25
• Adding AquaGuard 2 Activation Key	25
• BMS 4 - 20 mA Interface	26

3

Warranty & Registration

Manufacturer's product warranty	30
---------------------------------	----

Commissioning & Warranty Registration	31
---------------------------------------	----

1 Installation Guidelines

Before you start

Select a suitable location for installation - preferably in close proximity to the main system, protected from the public and environmental factors such as direct sunlight. A wall area of approx. 0.75 m. wide by 1.0 m. high is ideal for mounting your controller. A minimum floor area of approx. 1.5 m x 0.6 m below the controller is required for the chemical tanks. This will vary according to the number and type of chemicals being used for dosing.

It is important to consider elements of the surrounding environment when installing the equipment. It is a requirement to provide protection for accidental spills of chemicals and that includes any leaks that can develop from pump pressure lines. Some corrosive chemicals will damage materials used in construction of buildings, particularly roofing. Never assume that the equipment will not leak, under certain conditions that will occur. It is the responsibility of the installer to ensure that such events do not create damage that should have been avoided by correct site selection and the provision of adequate bunding at the time of installation.

Minimum system requirements

There are several minimum requirements that should be established BEFORE the controller is installed;

- Minimum 20 mm (3/4) take-off and line to supply sample water to the system,
- Minimum 12 litres/minute supply flow to ensure proper operation of sample readings, dosage and bleed off rates.
- Adequate bunding is provided for the system and chemical drums to prevent spills causing damage.
- Availability of approved connection to power. A 'clean' 220 - 250 vac 50 Hz @ 10 amps supply (some options may need more than one outlet, or increased current capability).

The terminal strips supplied with the controller activate a 240V AC supply rated @ 7A combined. These terminals are active when

the Relay Output for the specific function is activated, eg, pH terminal will go active 240Vac when the pH monitored value is outside the set-point. These outputs should be wired by a qualified electrician. The Neutral and Earth connections for each output must be connected to the commoning blocks using the terminals.

To install

Unpack the equipment and check for any damage. Ensure all parts are accounted for.

Assemble the inlet and outlet PVC valves on the sensor manifold. Remove the protective cap and fit the pH/ORP probe into the manifold.

Connect a 20 mm line from the circulating pump discharge line, or system common discharge header, to the inlet of the manifold. Connect a return line from the manifold outlet valve preferably in PVC pipe to the pump suction or common suction header.

Install chemical tanks as required, and ensure each dose pump discharge tubing is connected to the manifold injection points provided.

Run a flow of water through the system under normal operating pressures. Check for, and repair any leaks. The Aquarius Controller is now ready for use. Liaise with your chemical specialist for advice regarding any bunding requirements, floor drainage requirements and fresh water supply in the vicinity of chemical tanks. In addition check on local authority regulations for discharge of trade waste, chemical storage and hazards control etc.

For Pit, fit the ground reference probe to the system. The black wire should be placed in pot with probe. Refer to the drawing on page 9.

Maintenance and Care of Sensors

Foulants can lead to inaccurate sensor readings. Sensors should be cleaned and calibrated regularly using the following procedures.

Cleaning of Flow/Conductivity/Temp Sensor

Isolate the flow to the manifold.

Remove the locking nut from the Flow/Conductivity/Temp sensor.

Abrade the sensor surface with 300–400 grade wet-and-dry paper until the surface is clean, the two carbon electrode surfaces are clearly visible, and the surface wets out freely.

Ensure flow paddle is free from debris. Rinse the sensor in fresh water and replace it in the manifold.

Cleaning of pH/ORP sensor

Isolate flow to the manifold.

Remove the sensors from the manifold by loosening the lock nut and withdrawing the sensor from the manifold.

Rinse the sensors in fresh tap water and remove any visible fouling. This should be done carefully by lightly scrubbing with a tooth brush or similar.

Place the sensors in the Electrode Cleaner solution (AS9500) for about 5 minutes to completely dissolve any trace of inorganic foulants.

Remove and rinse thoroughly in fresh water before replacing it in the manifold.

Proceed to calibration or verification of sensors as outlined in the commissioning section.

Accessories and Spare Parts

Reagents

AS1413 -1413 uS/cm conductivity solution

AS7004 - pH 4 buffer solution

AS7007 - pH 7 buffer solution

AS5250 - 250 mV ORP solution (if used)

AS5475 - 475 mV ORP solution (if used)

AS4250 - pH 4.01/250 mV combo solution

AS7086 - pH 7.01/86 mV combo solution

Sensors (if included)

PR_FCT – Combination Conductivity, Flow and Temperature Sensor.

PR_pHORP – Combination pH, ORP and Ground reference Sensor or

IH20_5 - pH Sensor with 5m Lead

Peristaltic Pumps (if included)

AP_PERI_S_KIT – AP PERI SERVICE KIT (Maximum service interval - 12 mths)

Included in this Kit are the following

- AP_TUBE4824 (1)
- AP_INJECT (1)
- TUBESUCTION(2)
- TUBEDISCHARGE (2)

AP_PERI_O_KIT – AP PERI OVERHAUL KIT (Maximum service interval - 2 years)

Included in this Kit are the following

- AP_TUBE4824 (1)
- AP_INJECT (1)
- AP_ROLLBACK (1)
- AP_DWEIGHT (1)
- AP_LID (1)
- TUBESUCTION (2)
- TUBEDISCHARGE (2)

Test Meters required

HI9813 Portable pH/cond meter

HI8314 Portable pH/ORP meter

Routine Testing

The use of an Aquarius control system will automatically vary the dosages and maintain good conductivity, pH, ORP and disinfection control, even where there are wide fluctuations in system load or demand.

The principles of “Best Practice” and “Duty of Care” that are the responsibility of the system owner dictate that all systems should be routinely serviced and tested chemically and the results logged.

1 Installation Guidelines

Warnings

Chemicals used as part of the treatment program may be hazardous. Please refer to the Material Safety Data Sheets (MSDS) provided by your chemical supplier and ensure personnel involved are aware of the handling and safety procedures.

Please read and understand all safety warnings on chemical containers before servicing any dosing equipment.

Wear as a minimum - safety goggles and gloves when servicing the dosing equipment.

Do not mix concentrated acids and oxidising agents as explosion, and/or toxic and lethal gas may be evolved, and/or fire result. Keep all chemical containers sealed and free from contamination.

Salt water chlorinators draw high currents when operated. The controller is fitted with a Normally Open, Normally Closed Relay for activating the chlorinator. This relay is suitable to a max. of 10A. Please consult the chlorinator specs to determine current draw. If greater than 10A, the relay may only be used to activate a contactor which in turn control the chlorinator.

Regular Inspections and Maintenance

For optimum results and continued accuracy, the complete operation of the controller system

should be verified at least on a monthly basis.

All sensors should be inspected, cleaned and calibrated as necessary every month.

Both pH & ORP sensors age with time and temperature, and have a typical life span of 24-36 months depending on the application in which they are operating and should be replaced accordingly.

Where fitted, flow sensors, solenoid valves and wire strainers should be checked for correct operation and cleaned of any debris every month so they work efficiently.

Injection non-return valves and pumps should be cleaned and checked at least annually.


Sodium Hypochlorite being highly alkaline may lead to scale formation on its dose injector and this may require acid cleaning on a frequent basis.

On the peristaltic dose pumps, the squeeze tubes and roller block should be checked at least annually and should be replaced every 12-24 months.


More regular maintenance may be required for the larger 3.0 l/hr pumps, due to increased pumping rates.

Chemical suction and discharge tubes should be inspected monthly and replaced as necessary


Maintenance	1 Month	3 Months	6 Months	1 Year	2 Years
Clean and Calibrate FCT Probe	√				
Verify Flow ON/OFF	√				
Verify pH/ORP Probe	√				
Test Outputs	√				
Test Pumps/Solenoid Operation	√				
Clean and Calibrate pH/ORP Probe		√			
Check/Clean Injectors		√			
Inspect Suction/Discharge Tubing		√			
Check/Clean Solenoids			√		
Peri. Pump - AP Service Kit				√	
Peri. Pump - AP Overhaul Kit					√



Typical Installation Schematic



2 System Configuration



Aquarius Control Systems

Your new Aquarius controller system features a front panel that consists of:-

Screen

A 4x20 line alphanumeric display

Buttons

The six button key pad is the primary user interface. The buttons provide the means to navigate the screens and set the operational parameters for your desired treatment program.

READ: Used to display READ only screens.

SET: Used to display SET screens.

CAL: Used to access sensor calibration screens.

**↑ (Up) &
↓ (Down)
arrows** Used to scroll between screens

or alter values for input.

ENT (Enter): Used to complete or confirm an action.
This will move the process to the next programmable function.

AQUARIUS

C Series

V2.01.30

14:47:45 W2 11/08/05

pH = 7.47 COND = 1.48

ORP= 522 FLOW = ON

FAC= 0.45 TEMP =25.8

LSI= 2.02 ALARM= OFF

CALIBRATION MODE

CHOOSE CAL. MODE ?

UP/DOWN SELECT

PRESS ENT TO EXIT

Default Screen

The factory setting is to show the 'default' screen on power-up. The Aquarius 'default' screen displays Company Name, name identifier of the equipment, firmware version, and the current system date and time. If there is an active system alarm, details will be displayed on the fourth line instead of LSI and alarm reading. Users may also configure the controller to show the current sensor readings instead of the default screen. If the sensor readings screen is selected, all current values of measured parameters are displayed.

Calibration – Access from the CAL button

The following instructions provide a detailed explanation of the Probes, Conductivity, and Temperature Calibration. Calibration of the pH probe and verification of the ORP probe are very similar processes. When calibrating the probes the user has the option of setting both probes in combination or setting each probe individually. Only use individual calibration when a single probe has been replaced or adjusted.

Press the CAL button on the front panel. The calibration mode selection screen will appear on the alphanumeric display. By pressing the ↑ (Up) and ↓ (Down) arrows the user can cycle all of the calibration modes indicated in the menu tree diagram.

COMBO CALIBRATION ?

UP/DOWN SELECT

ENTER TO CONFIRM

Combination Calibration Mode

As both the pH and ORP sensors are contained within the one electrode it is possible to perform both pH calibration and ORP verification in one step. For this you will need Aquarius combination buffers.

Part Number: AS7086 - pH 7.01 & 86 mV

Part Number: AS4250 - pH 4.01 & 250 mV

CALIBRATION MODE

Erase WUM Totals?

UP/DOWN SELECT

ENTER TO CONFIRM

Use Water Usage Meter (WUM) Totals Mode

IM total value can be reset from here. Pressing ENT will bring it to a second screen for confirmation.

CALIBRATION MODE

pH CALIBRATION ?

UP/DOWN SELECT

ENTER TO CONFIRM

pH Calibration Mode

To calibrate pH separately press ENT for pH calibration. Then place the probe in pH solution and press ENT when ready. The screen will display the message 'PROBE STABILISING PLEASE WAIT'. When completed the screen will display the value and prompt the user to press ENT to continue. At this point, the menu will return to the 'CHOOSE CAL MODE ?' screen.

Part Number: AS7004 - pH 4.01

Part Number: AS7007 - pH 7.01

2 System Configuration

CALIBRATION MODE
ORP VERIFICATION ?
UP/DOWN SELECT
ENTER TO CONFIRM

ORP Verification Mode (if ORP is used)

To verify ORP separately press ENT for ORP verification. Then place the probe in the requested solution and press ENT. The screen will display the message 'PROBE STABILISING PLEASE WAIT'. Then rinse the probe in fresh water and place it in the second solution requested, press ENT when ready. The screen will display the message 'PROBE STABILISING PLEASE WAIT'. When this is completed the user will be prompted to press ENT and will be returned to the 'CHOOSE CAL MODE ?' screen.

Part Number: AS7250 - 250 mV

Part Number: AS7475 - 475 mV

CALIBRATION MODE
COND/TEMP CAL ?
UP/DOWN SELECT
ENTER TO CONFIRM

Cond/Temp Mode (if used)

To calibrate Cond/Temp press ENT for Cond/Temp calibration. Press the ENT key on the key pad to access the temperature calibration sub menu.

TEMPERATURE CAL
WATER TEMP. =28.6°C ?
UP or DOWN TO CHANGE
ENTER TO CONTINUE

Steps in Temperature Calibration

Conductivity is calibrated by first setting temperature and this is important or invalid performance may result. To set the water temperature sensor, enter the actual temperature (as read from a thermometer) or accept the temperature value displayed on the screen. The temperature value is changed via the ↑ (Up) and ↓ (Down) arrows on the key pad. To accept the reading displayed, press the ENT key on the key pad.

TEMPERATURE CAL
PROBE STABILISING

PLEASE WAIT

TEMPERATURE CAL
TEMPERATURE CAL OK

ENTER TO CONTINUE

The message screen changes to indicate 'PLEASE WAIT'. When the calibration is complete the screen will display 'TEMPERATURE CAL OK' press ENT on the key pad and the conductivity calibration screen displays.

CONDUCTIVITY CAL
PLACE PROBE IN SOLN
SOLUTION = 1.41 mS/cm
ENTER TO CONTINUE

Steps in Conductivity Calibration

This screen is used to calibrate the conductivity sensor. To begin, enter the actual conductivity of the solution being used for calibration. If using tower system water, the value is read from the independent conductivity meter. Or enter your calibration solution value into the screen.

CONDUCTIVITY CAL

PROBE STABILISING
PLEASE WAIT

CONDUCTIVITY CAL

COND. 1.41 CAL OK
ENTER TO CONTINUE

When performing a calibration, change the conductivity value via the ↑ (Up) and ↓ (Down) arrows on the key pad. If required after your calibration solution figure is showing on the screen, place the probe in the solution and press ENT and the screen will display the message 'PROBE STABILISING PLEASE WAIT'. Press ENT key on the key pad when complete and the screen will display 'COND. (VALUE) CAL OK'. Press the ENT key a second time and the menu will return to the 'CHOOSE CAL MODE ?' screen.

Note: It is important to clean the conductivity probe before calibrating conductivity.

Part Number: AS1413 - 1413 uS/cm

CALIBRATION MODE
Erase CALIBRATION ?
UP/DOWN SELECT
ENTER TO CONFIRM

Erase Calibration Mode

There may be times when the user decides to set the controller calibration back to factory defaults. This is achieved by erasing the controller's calibration data.

The user will be asked to confirm this action and once accepted the menu will return to the 'CHOOSE CAL MODE ?' screen. The controller will then have settings that are factory defaults as outlined in the product specification sheet. It is very likely that in this event the user will need to perform the calibration process again.

CALIBRATION MODE
Panel Selection
UP/DOWN SELECT
ENTER TO CONFIRM

Panel Selection Mode

While in calibration mode the user has the choice of viewing either the standard Aquarius default screen or having all sensor data displayed as the default screen. To make this selection press ENT and there will be a prompt to select the default option.

Controller Has
Factory Settings
Please Configure
Enter to Continue

Factory Alert Screen

The Factory Alert Screen provides a warning function and will display when configuration is required from factory settings. This screen prompts the user to start a major system setup.

AQUARIUS
S Series SN:000121
V2.01.30 CHK 02F7
BV1.0.18 19/01/05

Source Data Screen

The Source Data screen is accessed by holding down the SET key.



XX Series: Series of Controller
SN: Controller Serial Number
V2.01.30: Firmware Version
CHK: Firmware Checksum
BV1.0.18: Bootloader version
19/01/05: Date of Manufacture

2 System Configuration

Set Screens Menu

All Aquarius controllers come loaded with preset default values for all of the treatment program parameters. On start up the controller will operate according to those defaults. However, every application should have a planned treatment program developed. Decisions need to be made on what values are most appropriate for ORP, pH, Conductivity requirements. Once the program has been determined, it may be set in the Aquarius controller, as described in the following sections.

The SET button gives access to the thirteen separate screens which may be used in setting a water treatment program as shown in the following graphic.



Key pad Function

The convention followed here is: that the ↑ (Up) and ↓ (Down) arrow keys will cycle first through the screens and the ENT button will set the cursor position within the screen. The arrow keys are then able to adjust those values highlighted by the blinking cursor. Pressing ENT on completion will take the user to the next function. When the cursor is returned to the top left corner of the screen the arrow keys can be used to progress to the next or previous screen.

Note: Modes have the following meanings:

- OFF:** Output is SET OFF.
FLOW: Output only cycles while FLOW=ON.
(if Manifold is used)
CON: Output cycles continuously (for pit)
ORP: (Oxidation Reduction Potential) Output only cycles while the ORP output is ON.
DUTY: Regulates output capacity.
TIM: **Output only cycles while the Timer is ON**
TIM FLOW: Output only and cycles when flow is present

TIME & DATE
CLK=01:50:36
DAY=Mon WEEK=2
DATE=21/03/2006

Set Time and Date Screen

The current time, day, week, and date are important for managing the treatment program and timing of ORP, biocide control, and for time stamping the data log. Only two values are adjustable but each contains several components.

CLK denotes clock time in 24-hour format. Hours and minutes are set separately.

DATE denotes the current date. Day, month, and year are set separately. This screen also displays the day of the week which it calculates from the date and the week number according to the following outline. The week is determined by the controller and changes at midnight between Saturday and Sunday. Week is used in the set up of biocide dosing programs.

DATALOGGER

LOG INTERVAL = 30 mins
LOG PERIOD = 35 days

Set Data Logger Screen

This screen is used to set the data logging options. The options are shown below.

Log interval: [30 mins]

*Options: 1, 2, 5, 10, 15, 30, 60, 120, 240 (Expressed in minutes).
Use the arrow keys to cycle these selections.*

Log period - is a calculated value that the controller computes and is expressed in days. The data log file will hold approximately 2400 entries which means that the duration is a function of the log interval. E.g. a log interval of 30 minutes will produce a total log period of 35 days.

Set Alarms
IGNORE FLOW=OFF
REPEAT=Every Morning
IGNORE CAL=OFF

Set Alarms Screen

Allows the user to configure various alarm functions within the controller.

IGNORE FLOW: [OFF]

When set to ON disables loss of flow alarm.

Options: OFF/ON

Use arrow keys to cycle these selections.

REPEAT: [Every Morning]

Options: Every Morning/Every 4 hrs/Once only/Never.

Use arrow keys to cycle these selections.

IGNORE CAL: [ON]

When set to OFF enables out of calibration alarms.

Options: OFF/ON

Use arrow keys to cycle these selections.

Note: This option is only available with GSM Modem Option.

2 System Configuration

Set Alarms

PH:1
NAME:.....
NUM:.....

Set Alarm Screen - Name and Phone

Allows the user to enter up to three names and contact phone numbers to receive notification of system alarms via mobile phone sms alerts.
Only available when a Communications Kit is fitted to the controller

Options: (three phone numbers)
PH1/PH2/PH3 Use the arrow keys to cycle through these selections.
Press ENT to place the cursor on the NAME field and use arrow keys to select characters. Press ENT to select and move the cursor to the next character. Pressing ENT a second time will move the cursor to the NUM field. The same process applies for entering the telephone number, the arrow keys cycle numbers 0 through 9 and ENT to move to the next number.

Set Conductivity

mS/cm=1.48 SET=1.50
MODE = OFF
ALM = OFF LOCK=N/A

Set Conductivity Screen (if used)

Refer to Table 1. Adjacent.
Allows the user to set the conductivity options for the controller.
mS/cm is a read only value generated by the controller. It conveys the actual value measured by the conductivity sensor, in millisiemens per centimetre.

SET: [value from Table 1]
Options: Value range 00.20 to 10.00.
Use arrow keys to cycle these selections.

MODE:
[FLOW] *Options: OFF/FLOW/CON.*
Use arrow keys to cycle these selections.

ALM: [+/-]
Options:
+ (alarm if above specified value)
- (alarm if below specified value)
+/- (alarm if outside specified range)
OFF (Alarm disabled)
Use arrow keys to cycle these selections.

Table 1.

Models Conductivity	CT Series	C [x] Series	S Series	T Series	A & P Series
Options Available	Above	Above	Above/ Below	Above/ Below	Below
Default Mode	Above	Above	Above	Above	Below

When the cursor is on one of the alarm modes press ENT to change the numerical values associated with that alarm. Select from the values of 0.1, 0.2, 0.4, 0.8, 1.0, 1.5 and 2.0. These values are the range from the set point that will trigger an alarm. Press the ENT again to move to the next set conductivity item.

LOCK: is not applicable to Conductivity.
The controller will alert the user after five minutes if actual value deviates greatly from the set point value. This aids the prevention of false alarms.

ORP RL=OFF
 ORP=732mV SET=730
 DUTY=50% MODE=FLOW
 ALM =OFF LOCK=300

SET:

[value from Table 2] *Options:*
 Value range of 0 to 999 mV.
 Use arrow keys to cycle these selections

DUTY:

[50%] = Pump Dose Duty.
Options: Values in the range of 1 to 100%. Use the arrows to cycle these selections.

MODE: [FLOW]

Options: FLOW/CON/TIM/ OFF.

Use arrow keys to cycle these selections.

ALM: [+/-]

Options:

+ (alarm if above specified value)

- (alarm if below specified value)

+/- (alarm if outside specified range)

OFF (Alarm disabled)

Use arrow keys to cycle these selections.

Set ORP Screen (if used)

Not Available on all Controllers. Refer to table 2. Adjacent.

Allows the user to set the ORP options for the controller.

Table 2.

Models - ORP	CT Series	C [x] Series	S Series	T Series	A & P Series
Options Available	Not Fitted	Oxidising (Not Visible)	Oxidising (Not Visible)	Oxidising/ Reducing	Oxidising (Not Visible)
Default Mode		Oxidising	Oxidising	Oxidising	Oxidising
Unsafe minimum ORP warning	N/A	400	600	No warning	500
Unsafe maximum ORP warning	N/A	750	850	No warning	850
Default Values	N/A	500	725	500	550

When the cursor is on one of the alarm modes press ENT to change the numerical values associated with that alarm. Select from the values of 25, 50, 100, 150, 200, 300, and 400. These values are the range from the set point that will trigger an alarm. Press the ENT again to move to the next set ORP item.

Alarm defaults: Min: 400 / Max: 750.

The controller has factory defaults which will issue alarms when these values are exceeded.

LOCK: [OFF]

Options: (Preferred lockout period)

Value In the range of 10 to 990 minutes,

OFF - disabled

Use arrow keys to cycle these selections.

If the lockout time is greater than 10 the lockout function is active. The controller will then "lock out" output after the selected time has elapsed without the controller having reached its nominated set point for ORP. This is a safety feature to prevent overdosage in case of sensor failure.

2 System Configuration

```
Set pH
A SP=7.80    DUTY=50%
B SP=6.80    MODE=FLOW
ALM=ON @1.0  LOCK=300
```

Set pH Screen

Refer to Table 3. Adjacent.

Allows the user to set the pH options. This screen should never require changing whilst in a monitoring mode. pH is a read only value generated by the controller and is not a value that can be set from this screen.

Table 3.

Models - pH	CT Series	C [x] Series	S Series	T Series	A & P Series
Options Available	Not Fitted	Acid/ Base	Acid/ Base	Acid/Base	Acid (Not Visible)
Default Mode	N/A	Acid	Acid	N/A	Acid
Unsafe minimum pH warning	N/A	6.5	6.5	No warnings	6.0
Unsafe maximum pH warning	N/A	9.5	8.5	No warnings	Window 6.00-8.00
Default Values	N/A	8.20	7.40	Window 6.00-8.00	6.50

SET: [7.50]

Options: Values in the range 3.00 to 11.00

Use arrow keys to cycle these selections.

DUTY: [50%] = Pump Dose

Duty.

Options: Values in the range 1 to 100%

Use arrow keys to cycle these selections.

DOSE STATE: [A]

Options: A/B

Use arrow keys to cycle these selections.

The pH controller can dose both acid and base.

MODE: [FLOW] Options: FLOW/CON/OFF. Use arrow keys to cycle these selections.

ALM: [+/-]

Options:

+ (alarm if above specified value)

- (alarm if below specified value)

+/- (alarm if outside specified range)

OFF (Alarm disabled) Use arrow keys to cycle these selections.

When the cursor is on one of the alarm modes press ENT to change the numerical values associated with that alarm. Select from the values of 0.5, 1.0, 1.5, 2.0, 3.0, and 3.5. These values are the range from the set point that will trigger an alarm. Press the ENT again to move to the next set pH item. Alarm defaults: Min: 6.5 / Max: 9.5.

The controller will issue alarms when these values are exceeded.

LOCK: [OFF] Options: (Preferred lockout period)

Value In the range of 10 to 990 minutes,

OFF - disabled Use arrow keys to cycle these selections.

If the lockout time is greater than 10 the lockout function is active. The controller will then "lock out" output after the selected time has elapsed without the controller having reached its nominated set point for pH. This is a safety feature to prevent overdosage in case of sensor failure

Only use Flow mode when manifold is installed.

```
Set Water Usage Mtr
Makeup 1Plse=10.0 l
Bleed 1Plse=10.0 l
Bk Wash 1Plse=5.0 l
```

Eg,
1 Plse = 0.25l would be used if
water meter provides 4 pulses
per litre.

1 Plse = 10.0l would indicate 1
pulse per 10 litres.

Set Water Usage Meter (WUM) Screen

Allows user to set amount of water per impulse.
Use the ENT key to switch between the items. Then use the
arrow keys to cycle these selections.
Value for Makeup/Bleed/Bk wash can be set from Disabled to
1000 ltr per Pulse.

Water Meter Cable Connection

Water Meter for Makeup line is to be connected to mainboard
through the terminals for WM & Gnd.

Water Meter for Bleed line is to be connected to WUM board
through terminal WM1.

```
Set PROTOCOL
MODE=AQUAGUARD
```

Set Protocol Screen

Allows user to select either of two protocol options for interfaces to
external features.


MODE: [Aquaguard]

Options: Aquaguard/MODBUS.

Use arrow keys to cycle these selections.

READ READ Menu Functions

- Alarms
- Sensor Status
- Conductivity
- ORP
- pH
- Superchlorination
- LSI/FAH
- Protocol



The Read Status Mode:

Aquarius controllers offer a number of read-only
screens that show the status of the current treatment
program. These are read-only screens and cannot be
used to modify a program.

Moving Between Read-only Screens and Set
Program Screens.

It is possible to jump from a read-only screen to
the corresponding set program screen by pressing
the SET key. Similarly, the user can move from a
set program screen to the corresponding read-only
screen by pressing the READ key.

2 System Configuration

Alarm Read Screen

Alarms ALARM=OFF
REPEAT=Every morning
->.....

The alarm read screen shows the configuration of the system alarms. The second line of the display shows how often alarms will be retransmitted. The third line displays current active alarm.

Note: where multiple alarms are active the screen will briefly rotate each alarm into view.

Thus the following could appear on the third line display:

Temp:	Temp:
CAL ORIG	OUT OF CAL
Cond:	Cond:
CAL ORIG	OUT OF CAL
ORP:	ORP:
CAL ORIG	OUT OF CAL
pH:	pH:
CAL ORIG	OUT OF CAL
Conductivity	300s
ORP	300s
pH	300s

Sensor Alarms have a five minute delay. The 300s (Seconds) will count down to zero before the alarm is activated.

Sensors Status Screen

SENSORS STATUS
DATALOG=Int @30mins
TEMP=25.0°C CHEMS=OK
FLOW=ON

This screen displays the status of sensors.

FLOW:	ON/OFF
CHEMS:	LO/OK
TEMP:	Current Temperature of the System (in °C)
DATALOG:	The Interval set for Logging

Conductivity Read Screen (if used)

Conductivity RL=OFF
mS/cm=1.48 SET=1.50
MODE=FLOW
ALM=OFF LOCK=NIL

This screen displays the conductivity status.

RL (relay):	OFF/ON
mS/cm:	millisiemens /centimetre
SET:	the current control set value for Conductivity
FLOW:	ON/OFF
ALM:	Will flash a value if alarmed
LOCK:	Not available on Conductivity

For descriptions and information on setting these items, refer to the Set Conductivity Screen.

ORP Read Screen (if used)

```

ORP          RL=OFF
ORP=732mV    SET=730
DUTY=50%     MODE=FLOW
ALM =OFF     LOCK=300
    
```

This screen displays the ORP status.

RL (relay): OFF/ON
ORP: The current value of the ORP in millivolts
SET: the current control setting for ORP in millivolts
DUTY: The current dose pump duty set
MODE: ORP/FLOW/CON/OFF
ALM: Will flash a value if alarmed
LOCK: Lockout period in minutes or OFF

For descriptions and information on setting these items, refer to the section Set ORP screen.

Note: If LOCK is flashing the controller is exercising lockout. This can only be released after correcting the cause and visiting the Set ORP Screen.

The reset is achieved by toggling the lock OFF then re-entering the lock value.

```

pH    RL A=OFF B=OFF
A SP=7.80    pH=9.87
B SP=6.80    FLOW=OFF
ALM=ON @1.0  LOCK=300
    
```

pH Read Screen

This screen displays the pH status.

RL (relay): OFF/ON
pH: Current value of pH
SET: The current control set value for pH
DUTY: The current duty set
Acid/Base indicator: A/B
MODE: FLOW ON/OFF
ALM: Will flash a value if alarmed
LOCK: Lockout period in minutes or OFF

For descriptions and information on setting these items, refer to the section Set pH Screen.

Note: If LOCK is flashing the controller is exercising lockout. This can only be released after correcting the cause and visiting the Set pH Screen.

The reset is achieved by toggling the lock OFF then re-entering the lock value.

Water Usage Meter (WUM) Read Screen

```

Water Usage Meter
Makeup Tot= 2223.5 l
Bleed Tot= 1132.5 l
Difference = 1091.0 l
    
```

This screen displays the total water usage readings for Makeup, Bleed & their Difference. These values can be reset in the Calibration menu.

```

Water Usage Meter 1
Makeup 1Pise= 0.25 l
Makeup MTD= 1450.4 l
Makeup YTD= 8522.5 l
    
```

The corresponding screens display the Makeup, Bleed and BackWash water-meter readings. It also shows the usage as a Month to Date (MTD) & Year to Date (YTD) figure.

2 System Configuration

```
Water Usage Meter 2
Bleed 1Plse= 0.25 l
Bleed MTD= 1450.4 l
Bleed YTD= 8522.5 l
```

MTD figure will reset automatically on the 1st day of the new month.

YTD figure will reset automatically on 1st Jan.

The measurements in litres of each water meter will be data logged for the selected datalog period.

```
Water Usage Meter 3
BkWash 1Plse= 0.25 l
BkWash MTD= 1450.4 l
BkWash YTD= 8522.5 l
```

Note: Changing of log intervals within the time period will result in inaccurate readings in AquaGuard 2. Log intervals is recommended at 30min which allows for 1 month worth of data.

```
PROTOCOL BD=115200
MODE=AQUAGUARD
```

Protocol Read Screen

This screen displays the selected protocol mode of the controller.

BD: 115200/9600

MODE: AQUAGUARD/MODBUS

Slave Addr: Current address assigned for MODBUS

TX: Current status of transmit

RX: Current status of receive

ERR: Current indication of communication errors

For descriptions and information on setting the protocol, refer to the section Set Protocol Screen.

For further instructions on the operation of this interface refer to AquaGuard Brochure and Manual

Tank Alarm

Tank alarms come in two sizes TANK_ALARM_SM (500mm) complete with 3m suction tube, drum weight and 3m connection cable or TANK_ALARM_LG (1000mm) complete with 5m suction tube, drum weight and 5m connection cable.

Tank Alarms can be configured for closed contact on empty (default) or open contact on empty. To change, remove circlip from bottom of Tank Alarm and reverse the float.

Designed for simple installation. Simply cut or drill 25mm hole in the drum cap, mount the compression gland into the cap, insert the Tank Alarm through the bottom of the gland, adjust height to desired depth and tighten compression gland.



For wiring into Tank Alarm Box, refer to diagram on the left.

Data Logging and Communications Set up

Data logging facilities are a standard in all "C" series controllers, and with the Data Log interval set to 30 mins - over 4 weeks of data logged on a 24/7 basis, can be stored before it is over written. See Set Data Logger Screen on page 15.

Down loading the Data Log

The data in the data log can be retrieved in a numbers of ways namely -

1. The data log can be down loaded locally to a laptop using the **Free** HyperTerminal program available in Microsoft Windows program, via a Serial cable attached to a laptop and to the DB9 connector fitted internally in the controller.
2. If a GSM modem and a SIM data card have been fitted, the data log can be retrieved remotely by again using HyperTerminal.

Both of these methods retrieve the data log in text format which will need further importation into an Excel spreadsheet for trending and graphing for reporting means.

3. Using AquaGuard 2 (30 day trial version) or AquaGuard 2 + Activation Key, allow for the data to be download into a database and with direct importation into an Excel spreadsheet - CWT_Graphs.xlt template to automate the graphing, summary, and trending charts, and speed up reporting. Use of a serial cable and a laptop allows for local download as in No. 1 above.
4. Where a GSM modem with a SIM data card has been fitted - full remote control is available using AquaGuard 2 software as in 3 above, plus alarms to 3 phones, and remote start up of disinfection, or changes to set points - all from the PC or laptop in your office or car.

HyperTerminal Setup

1. Start **Programs, Accessories, Communication, HyperTerminal** to start the program (the program that is run is **hypertrm.exe**)
 2. Start a session called **Download** (or another meaningful name).
 3. Select using '**Direct to Com 1**' (the most likely communications port). It will then ask for settings of COM1. Select **9600 baud, 8 bits, no parity, 1 stop bit and no flow control**.
 4. Select **Transfer Capture Text** and name your file as normal download file names i.e. Site-month-year.txt (e.g. **XYZ0406.txt** for a April 2006 download at site XYZ).
 5. Press **"?"** then downloads will start as normal.
 6. At the end of the download, select **Transfer Capture Text Stop**.
 7. The file with a .ht extension will be saved by selecting **File Save**.
 8. Make a short cut on the desktop to this file. All the settings will then be configured so when you go into it from the short cut start from step 4.
- We now have the downloaded data from the controller in text form. The txt file can now be imported into an Excel spreadsheet to obtain trend graphs etc..
9. Open up the Excel spreadsheet, it will ask you what file you would like to import. Select the file as named in step 4.
 10. The data will import into the spreadsheet and you can commence to set up trend reports, graphs, etc.

2 System Configuration

GSM MODEM SET UP

SIM Card setup request from Service Provider

1. Aquarius recommends using Telstra as a Service Provider for Data Communications in Australia - between AquaGuard and the Water Treatment Controller.
2. When requesting a new account from your Service Provider, the following information should be given to them in order to receive a SIM card that is **data enabled** and has the **correct phone number**.
 - a. Advise the Service Provider that you require a **Data enabled SIM Card**
 - b. The account should have **no voice message service**
 - c. The account should be stripped of all auxiliary services
 - d. Ask for the **Data Telephone Number as well as the Voice Number of the account**
3. Once you receive your new SIM card perform the following functions
 - a. Remove all password protection from the SIM. i.e. **no Pin Numbers to switch on**. This can be done by inserting the SIM card into a telephone and removing the PIN activation on start up
 - b. Insert SIM card into the modem by removing the black cover situated below the LED, lifting the SIM holder, and placing the SIM in the slot. Remember to push the SIM card holder into the **LOCK position**.
 - c. Record the Data telephone number in a safe place. Aquarius recommends placing a sticker with the number on the modem itself.
4. All messaging and other features can now be setup via AquaGuard.
5. Should there be any further problems in accessing data or receiving SMS messages from the SIM card, **Please contact the Telstra Help Desk on 1800 010 253 Option 2 or your Service Provider who are equipped to deal with Data Accounts etc.**

Programming a GSM modem –

You communicate with your modem via a serial communications program such as HyperTerminal, Telix. etc. Plug the cable provided from the modem into the serial port of your computer.

Set up the communications program for direct connection to your serial port (COM1, COM2, at 9600 Baud, 8 Data & 1 Stop Bit, with no Parity or Flow Control. The **AT&V** command (**+ENTER**) should now return the current modem settings to the screen. Once you have established communications with the modem you can begin the Set Up using the following commands.

Modem Alarm Setup for “C” series controllers.

Check Registered phone numbers

AT+CPBR=1,10

Delete all registered phone numbers

AT+CPBW=<index>

Enable the use of text mode parameters

AT+CSDH=1

Set text mode parameters

AT+CSMP=17,167

Switch the module to text mode

AT+CMGF=1

Save the settings

AT&W

Program the phone book

AT+CPBW=1,"0421XXXXXX",129,"Berts Mob"

AT+CPBW=2,"0419XXXXXX",129,"Freds Mob"

AT+CPBW=3,"0419XXXXXX",129,"Toms Ph"

Index's 1 to 10 to be used for alarm messages.

You can do things like: -

List all the phone numbers

AT+CPBR=1,10

To send a test sms message

AT+CMGS="<phone number>"<enter>alarm message here<CTRL-Z>

SMS call centre number -

If you're having trouble sending an SMS from the GSM Modem it may be that the SMS Call Centre number on the sim card is incorrect. To check this place the SIM card into a mobile phone then go into **Messages => Message Settings => Message Centre Number**. The number here in Australia should be **+61418706700**. If not, change the number and save it to the SIM card before returning it to the GSM Modem.

Signal Strength -

You can check the signal strength at your location by entering the AT+CSQ command. This can be done with or without the SIM Card in the Modem. A 0-33 response is OK. If you get 99 back, there is no Network available.

Using AquaGuard 2 for remote Communications

Installation

The AquaGuard 2 Software Program CD needs to be installed on a PC or laptop to be used for communications and be within its 30 day free trial period, or the AquaGuard 2 Activation Key CD must be purchased and installed on the PC to allow communication with the particular controller.

AquaGuard 2 can be used for communications and downloads in two modes -

Locally - connect the laptop with AquaGuard 2 installed to the DB9 connector on the controller located internally on PCB, using a serial cable.

Remotely - with a GSM modem and SIM data card installed in the controller - AquaGuard 2 can be used to communicate between a laptop, equipped with a mobile phone and Bluetooth adaptor, via the GSM network to the controller

See AquaGuard 2 User Manual for full details.

Troubleshooting of AquaGuard 2

AquaGuard software has been extensively tested during both development and site trials. However, the rate at which PC hardware and software is developing make it impossible to ensure that AquaGuard will operate in all situations. The greatest problem facing new installations is to ensure that the software can be installed and that correct communications can be made.

Problems with Software Installation.

If error messages occur while AquaGuard is being installed, record the details of the error and details of the PC that AquaGuard is being installed onto such as speed, RAM size, operating system (Windows 2000 etc), serial devices fitted to the PC, and free disk space. Relay this information to Aquarius Technologies and our software team will endeavour to find a solution.

Problems with Communication.

If correct communications cannot be established, record any error messages being shown and perform the following troubleshooting steps to ascertain the problem:

Determine that the modem has been set to operate at 9600 baud, 8 bits, 1 stop, and no parity.

Determine that the modem is initialising by observing flashing LEDS on the modem at the start of the connection.

Use HyperTerminal to communicate with an external PC such as in an IT department or within Aquarius Technologies.

Ascertain if the modem is connected to the site and the controller is receiving the incoming call and is auto-answering.

Supply Aquarius with the site details to ascertain if a connection can be made from another PC.

2 System Configuration

BMS 4 - 20 mA. Interface

Introduction

The Building Management System output option for your controller provides a local BMS/PLC/SCADA system with 4-20 mA signals proportional to measured values, along with ON/OFF, clean contact relays for Alarm, Flow, and the status of all output relays.

Connections

All connections for BMS outputs are made via the BMS Connector Board, cabled through spare glands in the base of the enclosure. The BMS Connector Board provides clear labelling of all 4-20 mA and relay status outputs. The configuration of the event outputs is discussed below.

4-20 mA Outputs

The BMS output option is available in 4 channel ("C" series) or 8 channel configurations (8 channel KPI only), with 4-20 mA signals proportional to Temperature, Conductivity, pH and ORP, (along with umPY and PIT rates on two metals for KPI 3 series controllers.)



Flow and all available relay outputs.

Relay numbering is consistent within each family of controllers, but dynamic across the full range, so relay numbers may change depending on your software configuration. The relay numbering for each software configuration is easily obtained by running the Test Outputs routine.

To enter the Test Outputs routine, press and hold the **READ** key for 5 seconds. Now press the **ENTER** key to move the cursor to the **MAN/AUTO** selection. Press the **DOWN** arrow key to select **AUTO** Test outputs operation. The controller will now cycle the output relays from REL1 through all available relays for 5 seconds each. As each output turns ON, the module and relay number are displayed in the Test Outputs window as follows:

Line 3: RL1 – pH ON (5)

Flow and Alarm relays are common across all controllers and are clearly labelled on the BMS Connector Board.



It is recommended that a 250 Ohm sense resistor is used at the BMS end of the connection for each 4-20 mA input – providing the BMS a 1-5 volt DC input across the range of measurement.

Note: In cases where the BMS requires a 2-10 volt analog input (500 Ohm sense resistor), the 4-20 mA output may only be accurate up to 95% of the maximum scale.

Event Outputs

Both the 4 channel ("C" Series) and 8 channel (KPI 3) BMS options provide for ON/OFF, clean contact switching for the current status of Alarm,

The COMMON of each Event Output relay can be supplied by a USER signal (+5, +12, etc, from BMS into RLY(S) COM) or use an internal +12 volt DC signal from the controller (for isolated inputs). This selection is made by placing the jumper on JP2 to either +12V or RLYS COMM.

The jumpers on JP1 are connecting each Event Output relay COMMON to the supply selected with JP2 (to save on external wiring – in most cases a common supply is sufficient). By removing these jumpers the user can choose to individually wire each relay, providing true clean contact switching for all outputs.

Conversions to Engineering Units

Each 1 - 5 volt DC analog input will need to be converted back into its appropriate unit of measurement.

Conversions for each input are as follows:

Parameter	Conversion	Units
Temperature	$(0 - 99.9) = ((\text{value}) - 1) / 4 * 100$	°C
Conductivity	$(0 - 9.99) = ((\text{value}) - 1) / 4 * 10$	mS/cm
ORP	$(0 - 999) = ((\text{value}) - 1) / 4 * 1000$	mV
pH	$(0 - 14.00) = ((\text{value}) - 1) / 4 * 14.00$	pH
Corrosion Rates		
as umPY1	$(0 - 1000) = ((\text{value}) - 1) / 4 * 1000$	umPY
as PIT1	$(0 - 1000) = ((\text{value}) - 1) / 4 * 1000$	PIT
as umPY2	$(0 - 1000) = ((\text{value}) - 1) / 4 * 1000$	umPY
as PIT2	$(0 - 1000) = ((\text{value}) - 1) / 4 * 1000$	PIT

Note: (value) = DC volts @ input = 4.00 Volts

Example: pH = $((4) - 1) / 4 * 14.00$
 $= (3) / 4 * 14.00$
 $= 0.75 * 14.00 = 10.50 \text{ pH}$

Testing

Once all connections have been made and all conversions entered into the BMS, the BMS interface must be verified.

For all analog inputs the reading on your BMS display should be within 1% of the reading displayed in the data display window on the controller. If the BMS allows, these readings can be calibrated to more accurately represent the controllers' reading.

If one or more readings is out of tolerance or cannot be calibrated check your conversions and record voltages at the input. If the voltage is OK the problem is most likely in the conversion. If the voltage is not OK, check the sense resistor value and all cabling. LED's L1 thru 8, on the 4-20 Interface Board, illuminate to highlight open circuit or high resistance current loops.

For testing of Event Outputs, run the Test Outputs routine whilst watching the BMS display. You should see each relay output cycle ON for 5 seconds then OFF. Turn Flow ON and OFF and watch for the flow indication at the BMS. Set an Alarm in the controller (remove sensor, alter SET point etc.) and look for an Alarm indication at the BMS.

Useful Contact Information

Aquarius Technologies Pty Ltd

ABN 94 010 393 254

Technical Support:

Phone: + 617 3274 4750

Fax: + 617 3274 4736

email: techsupport@aquariustech.com.au

Postal Address:

PO Box 71
 Coopers Plains Q 4108
 Australia

Delivery Address:

1/21 Richland Avenue
 Coopers Plains Q 4108
 Australia

Trading hours:

08:00 to 17:00 Monday - Friday
 Australian EST

Record details of your controller here:

Controller:

Serial Number:

Date Installed:

Pumps:

1 - serial number

2 - serial number

3 - serial number

4 - serial number

5 - serial number

6 - serial number

2 System Configuration

These pages are intentionally left blank.

3 Manufacturer's Product Warranty

AQUARIUS TECHNOLOGIES PTY LTD

Manufacturer's Product Warranty Definitions

"Aquarius" means Aquarius Technologies Pty Ltd ABN 94 010 393 254

"Product" means:-

- (i) goods purchased from Aquarius that have been manufactured in whole by Aquarius; and
- (ii) the Aquarius manufactured components in third party goods.

"Buyer" means any person or entity who buys product for consideration from Aquarius.

"The Law" means and includes the Trade Practices Act (Commonwealth) 1974 and relevant State and Territory fair trading or other consumer protection legislation and includes any statute amending, consolidating or replacing the same from time to time.

Warranty

1. Aquarius warrants that:-

- (i) all Product is produced under a Quality Assurance System to ISO9001:2001 standards;
 - (ii) the Product conforms to the written description in the purchase order quotation and related purchase documentation accepted by Aquarius in writing except for such defects that are normally regarded as being commercially acceptable;
 - (iii) the Product will be reasonably fit for the purpose of use described by Aquarius, however Aquarius accepts no responsibility for third party misrepresentation;
 - (iv) the Product will be of merchantable quality and free from defects in material and workmanship.
2. If within twelve (12) months (from either the date of purchase by the Buyer or the date of installation, whichever is the earliest) the Buyer gives to Aquarius written notice that the Product does not correspond with the description or is defective (and such defect could not have been detected at the time of delivery) and Aquarius agrees then, PROVIDED:-
- (i) that Aquarius, via its customer service department, is contacted promptly;
 - (ii) that the Buyer supplies to Aquarius sufficient proof of purchase, the model number and serial number of the Product;
 - (iii) that if necessary, the Product is returned by prepaid freight to Aquarius Technologies P/L factory headquarters:-

- (a) within fourteen (14) days of detection of the alleged fault; and
- (b) in the same order and condition as that in which it was delivered
- (c) packaged to prevent any damage in transit;
- (d) that the product contains the return authorisation number, customer identification number, and return delivery details

AND

- (iv) if any alleged defect or failure to correspond with description has not arisen from:
 - alleged defect or failure to correspond with description
 - improper or incorrect installation or site preparation;
 - improper maintenance, adjustment, modification or contamination caused or induced by the Buyer;
 - the Product being used or attempted to be used in a manner which is beyond normal commercial capacity and application of the Product;
 - any abuse or misuse of the Product including operation of the Product in circumstances where there may be subject to irregular electrical supply;then, Aquarius will at its option either:-
 - (v) repair any part of the Product which is proven to be defective in material or workmanship upon the Aquarius' examination. The repairs will be carried out by Aquarius personnel or persons appointed by Aquarius at Aquarius premises or at the site or premises of the supplier to Aquarius. This warranty does not include removal, installation costs, or liability exceeding the selling price of the Product. Aquarius warrants that all repairs on returned Product will be free from defects in materials and workmanship for a period of sixty (60) days; or
 - (vi) replace the Product.
3. The Buyer will be liable to Aquarius for all reasonable costs incurred by Aquarius in relation to the investigation, analysis and testing of a Product which are not defective in the reasonable opinion of Aquarius.
4. In no circumstances will Aquarius:-
- (i) incur liability in respect of, or arising out of, or in connection with harm or injury suffered or incurred by the Buyer;
 - (ii) incur liability in respect of any special consequential direct or indirect loss or damage;
 - (iii) accept liability for the cost of any repair or attempted repair by the Buyer by any unauthorised third party.

Commissioning & Warranty Registration

This form should be completed by the Equipment OWNER promptly after installation & commissioning. When signed it should be faxed to Aquarius Technologies Pty Ltd on +617 3274 4736. This will ensure the equipment details are logged to our confidential Warranty Database to activate your warranty registration and assist our ability to process any future service inquiries.

Please print all details except for signatures

Model: Serial No:

Date of Installation:

The above equipment was satisfactorily commissioned for:

Owner (Company Name):

Address 1:

Address 2:

State: Country:.....

Signed for and on behalf of the Equipment OWNER

Name:

Date: Signature:

Commissioning Company Name:

Address:

State: Country:.....

Technician Name

Date: Signature:.....

Thank you for your very valuable support, purchase and installation

Aquarius Technologies Pty Ltd

3 Warranty Registration

Faxing Instructions for Registration

Fax this form immediately to

Aquarius Technologies Pty Ltd
+617 3274 4736

Upon receipt your controller will be registered in our equipment database. This will provide a ready confirmation of the actual equipment installed, and the configuration characteristics at your specific installation. This information will assist greatly with our treatment of technical and service inquiries in the future.

